This RS485 12v DC Combiner allows you to connect up to four RS485 control devices such as DVRs, Matrix units and RS485 keyboards that will control from 1 to 128 PTZ dome cameras. This combiner overcomes control problems as it utilises a shared control bus.



General Information

- 1. The ACC704 RS485 combiner requires a **12v DC** regulated power supply. An in-line 1A power supply and lead with a 13amp plug is supplied free with each unit.
- 2. Do not attempt to disassemble these combiners. In order to prevent electric shock, do not remove screws or covers. There are no user-serviceable parts inside this unit.
- 3. Always use and adhere to current electrical safety standards to install and use the RS485 Combiner. The RS485 cables should be kept way from high voltage equipment such as mains cables and especially fluorescent lights. Using an anti-surge protection device is recommended to prevent damage to this unit from lightning and mains surges. Damage caused by lightning or mains voltage surges is not covered under the warranty.
- 4. Do not operate in areas exceeding the stipulated limitations concerning temperature, humidity and power supply.
- 5. Always ensure that when connecting RS485 control equipment that the correct polarity is observed.

<u> Power</u>

Connect a 12vDC regulated power supply with 2.1mm jack to the power input.

Input Controllers


This RS485 combiner allows you to connect up to four RS485 inputs from controllers such as DVRs, Keyboards and Matrix units. All four inputs can be activated at the same time. The input devices can have any protocol, baud rate and ID.

Output RS485 Bus Line

The RS485 output bus line allows connection of up to 128 PTZs in parallel with different protocols and baud rates. Commands from the input devices are directed at all the PTZ cameras connected and each PTZ will respond to commands that match the settings in the respective PTZ camera.

It is recommended to use one twisted pair of CAT5 for each of the RS485 inputs and outputs. The maximum connection range for each output is 1200 metres using CAT5. Ensure that the termination connection is switched on in the last PTZ camera or longest run. Note that you do not connect baluns on data lines.







Example

In the diagram to the left there are three DVRs and one PTZ keyboard connected from the RS485 to the A and B connections on the rear of the ACC704. The DVRs are 4 channel Alien DVRs and each have the ability to access 4 PTZ cameras that are on different protocols and baud rates. The office wants to also access one PTZ using a keypad. Using this RS485 Combiner you have an easy way of connecting the RS485. Whatever commands are issued by any of the DVRs or by the keyboard, will be sent to all the PTZs and those matching the correct protocol, baud rate and address will process those commands. If the same PTZ camera is accessed by more than one device, control is gained by each device that sends a successful command string.

NOTE: The RS485 output follows normal RS485 conventions allowing you to use the star connection method if needed.




Front Panel Description



Status Indicators

- 1 ~ 4 status light flickers green when receiving data
- 5 power light red when unit powered up
- 12vDC power input



- RS485 OUT A+ B- connections (same as T+ and T-)
- 2 ~ 5 Connections for A+ B- for RS485 Inputs

Technical Specifications

Power Supply	12vDC 1A regulated
Consumption	<100mA
RS485 Inputs	1 ~ 4
RS485 Output	1 (1 ~ 128 devices)
Dimensions	118 x 111 x 37mm
Compatibility	RS485, RS422

All specifications are approximate. Antihum.com reserves the right to change any product specifications or features without notice. Whilst every effort is made to ensure that these instructions are complete and accurate, Antihum.com cannot be held responsible in any way for any losses, no matter how they arise, from errors or omissions in these instructions, or the performance or non-performance of the equipment that these instructions refer to.



documents means that used electronic equipment must not be mixed with general household waste. For treatment, recovery and recycling please return this unit to your trade supplier or local designated collection point as defined by your local council.

This symbol on the products and/or accompanying

WEE/CG0783SS